

Questions from Board Members

Board Meeting Agenda - August 18, 2020

Superintendent's Report

I saw in your superintendent's update that one media technician was hired. Does that cover tech support or is that specifically for other media support?

No, not tech support. Media techs support site libraries.

Consent Agenda

Item H-10: Personnel - I was wondering if I could get an idea of the approx split between replacement and new positions for the almost 60 teachers hired. Thank you!

A total of 72 were hired, which included 18 new certificated positions.

Action Agenda

Item I-4:

1) The contract is for Phase1 Increment1 & includes clearing of the entire site, utilities, sound walls, building pad. Given this:

a) What is the extent of underground utilities included in this first package, that pertain to phase2?

All wet utilities to the extent possible are being installed in this increment. This includes fire water for hydrants and for the building fire sprinkler systems, domestic water, sanitary sewer, and stormwater systems. In all cases the mainlines are included with stub outs for future tie in by the increment 2 contractor.

The dry utilities of power, data, gas and phones are going to be part of the increment 2 contract.

b) Please provide information regarding the sound walls. Where, & what are these made of & what will these look like?

The temporary construction sound wall is to be located on all 4 sides of the project and to be at least 12' high. The exact construction will be submitted and approved by the architect and the DUSD team. It will need to be constructed of a solid material like wood and be able to withstand wind and potential seismic activity.